




North



VENTILATION SCHEME

Recommendations

1. Computed Capacity at 16' depth and .48 cwt per cu. ft. $(.42 \times 90 \times 42 \times 16) - (.42 \times 90 \times 7 \times 16) = 19,657$ cwt
2. Fan Capacity 19,500 cfm based on 12ft per cwt. Must deliver at 1/2" static pressure.
3. Consider a fresh air inlet and exhaust openings not any smaller than fan shroud.
4. Completely seal Plenum chamber from bin.
5. Inlet opening to fan should not be smaller than fan shroud.
6. Space at end of duct 3/4" to 1"
7. Cribbing on exterior wall maybe closed below duct except for a approximately 3" allowing some air to flow up along the outside wall.
8. Install fan as near the peak to bring return air along ceiling of storage.
9. If additional small fan are available they maybe installed near work area pushing air toward Plenum chamber.
10. Combined Cross sectional Area of Ducts should add up to be 20ft. sq.
11. The 2' spacing between center duct and outside wall is a maximum. The center duct should be near to to have a cross section area of 10ft² (approx.) need for good air flow.
- 12.



Note: If you use your 8'x26" A' duct you will need the 12'x6" duct system on exterior wall. I would rather see you use the 8'x6" A' duct in the center with the 8'x3' ducts on the exterior walls. The 2' between ducts is along ways to move air horizontal and your present A' duct is small and might not do the job you want it used in middle of storage. It is also short on cross sectional Area to use along the outside wall.

PREPARED BY:
NDSU EXT. AGR. ENGR.

POTATO STORAGE VENTILATION
INLET/EXHAUST DAMPER
NDSU EXT. AGRIC. ENGINEERING
1970 PWR
N.D. 835-3-2 1 SH.

PROPOSED VENTILATION SYSTEM